

### Corrigendum No. 1/ IT Equipment's/LNMIPAT/02/2025

In continuation to the Tender Document No IT Equipment's/LNMIPAT/02/2025-26 Dated 26.08.2025 and with reference to the Pre-Bid Meeting held on 11.09.2025, the following corrigendum is hereby issued:

Exiting Provision RFP	Modified Provision
(i) In page no.10, serial no-2- Bidder should have Average Annual Turnover Min INR 10.00 Crores during the last five financial years as on March 31, 2025.	Bidder should have Average Annual Turnover Min INR 10.00 Crores during the last five financial years as on March 31, 2024.
(ii) In page no.28, serial no-20- built in OS Android 13.0 or windows 11.	built in OS Android 13.0 and above or windows 11.
(ii) In page no.30, section H- 1KVA line interactive UPS.	1KVA Online UPS System with battery inbuilt having following Specification-

#### Specification-UPS-

Technical Specifications for 1KVA Online UPS System with battery inbuilt		
SN	Specifications	Requirement
1	Capacity (in kVA / kW)	1kVA/.9kW 1-Phase Input / 1-Phase Output with Battery Inbuilt
2	Input Voltage Range	110-300VAC (load dependent)Range (Full Load) 160 ~300VAC Range for 60 % load - 110 ~160VAC
3	Nominal Input Frequency	50 or 60Hz
4	Nominal Output voltage	200/208/220/230/240 VAC
5	O/P Voltage	O/P Voltage at 200V also.
6	Charging Current	1 A
7	Efficiency	88%
8	Out put Socket	Programmable Output Socket
9	Backup Required	168 VAH
10	Battery Bank Voltage	24 VDC
11	USB Port should be available	There should be provision for USB port also in the UPS.
12	RS232 Port should be available	There should be provision for RS232 port also in the UPS.
13	EPO Port should be available	There should be provision for EPO port also in the UPS.
14	Manufacturer	QMS: As per ISO 9001: 2008 EMS: As per ISO 14001: 2004 OSHAS: As per ISO 18001: 2007
15	Product Safety Certifications	BIS Certification. Manufacturer shall have TL 9000 certificate in India & Factory Lab of Manufacturer shall be NABL Accredited in India (All certificates for Indian Factory). Third party type test & environmental report. VAPT Certification for SNMP
16	Others	Bidder to provide MAF specific to this bid Warranty on UPS 3 years and Battery 1 years

All other terms and conditions of the tender document shall remain unchanged.

This corrigendum shall be treated as an integral part of the tender document.

  
Registrar